



Water for All: Conserve, Value, Enjoy

Tel: 67313253

Your Ref :  
Our Ref : WRN/ (Please quote our file number in reply)  
Date : 16/11/2015

DEAR MR

**SANITARY PLUMBING AND DRAINAGE WORKS FOR PROPOSED 2 NOS. OF 3-STOREY  
TEMPORARY ANCILLARY WORKERS' DORMITORY (NOS. WORKERS) FOR CONTRACT  
ON LOT MK AT  
PROJECT REF NO:**

**SEWERAGE CLEARANCE FOR TEMPORARY OCCUPATION PERMIT (TOP)**

1. This is to acknowledge receipt of your Certificate of Completion and Inspection for Sanitary Works dated 10 July 2015 & 13 November 2015 for the above development.
2. Our officer has inspected and accepted your completed sanitary works dated 29 October 2015. The Sewerage clearance for Temporary Occupation Permit (TOP) is now granted subjected to the Developer/Owner shall comply fully with the following conditions/requirements:
  - The use of the existing holding tank shall serve not more than workers residing on site. workers from the workers' dormitory & staff & workers from the site office and canteen.
  - Developer/owner is required to make a new application if there are changes to the capacity (nos. of workers) of the dormitory.
  - Developer/Owner shall engage a NEA's License wastewater collector to regularly empty the temporary holding tank by tankers to transport the used water to a designated Water Reclamation Plant for disposal.
3. The QP may apply to CBPU (NEA) for clearance for Temporary Occupation Permit (TOP) if he has also complied with the drainage, pollution control and environment health requirements.
4. We wish to highlight that only sanitary appliances, pipes and fittings and manhole/inspection chamber frames and covers of a type complied with the standards and requirements prescribed by PUB shall be used in the sanitary/sewerage works for the project. QP shall obtain from the suppliers the valid full test reports or conformity certificates for the sanitary appliances, pipes and fittings and manhole/inspection chamber frames and covers and submit for verification upon request by PUB. PUB may conduct checks on site if the appliances & fittings actually installed are indeed as declared.

Yours faithfully,

*(Sent by e-corenet)*

**YEO KHOON JOO**  
AUTHORISED OFFICER  
WATER RECLAMATION (NETWORK) DEPARTMENT

CC  
OWNER/DEVELOPER:  
REGISTERED INSPECTOR - ARCHITECT:  
CONTRACTOR/PLUMBER:

CE (CBPU)  
Attn: MR LONG HAN BOON

***- We have no objection to the issue of Clearance for TEMPORARY OCCUPATION PERMIT for the above project.***